

## PUBLIC UTILITIES REGULATORY COMMISSION

## GHANA GRID COMPANY (GRIDCo) KEY REGULATORY INDICATORS

## 2023 Third Quarter Performance

SYSTEM SUPPLY INDICES	UNITS	Q3
Total Energy Transmitted	GWh	5586.98
Max System Demand	MW	3280.00
Average Demand MW	MW	2530.34
Load Factor	%	77.14%
Transmission Line Availability		
69KV	%	99.82%
161KV	%	99.77%
225KV	%	98.66%
330KV	%	99.60%
System Availability	%	99.76%
Index of Transmission Reliability	%	99.89%
Number Of Lines Outage		
Planned		96
Unplanned		271
Reliability Indices		
SAIDI (Excluding Planned Outages)	hh:mm	01:14
SAIFI (Excluding Planned Outages)		1.53
Average Feeder Availability		
Including Planned Outages		99.92%
Excluding Planned Outages		99.94%
Worst Performing ECG Feeder		
Feeder Name	ID	20F2
Availability	%	99.10%
Worst Performing NEDCo Feeder		
Feeder Name	ID	62F1
Availability	%	99.43%

SYSTEM SUPPLY INDICES	UNITS	Q3
ECG Feeder Availability		
Including Planned	%	99.93%
Excluding Planned	%	99.95%
NEDCo Feeder Availability		
Including Planned	%	99.86%
Excluding Planned	%	99.90%
Load Shedding Events		
Automatic Load Shedding (AFLS)		
Number of incidences		2
Total Duration	hh:mm:ss	09:01
Manual Load Shedding		
Number of incidences		71
Total Duration	hh:mm:ss	139:35:00
Frequency Deviation		
% Of times frequency was within limits	%	55.05%
% Of times frequency was outside limits	%	44.95%