

## PUBLIC UTILITIES REGULATORY COMMISSION

## GHANA GRID COMPANY (GRIDCo) KEY REGULATORY INDICATORS

## **2022 First Quarter Performance**

SYSTEM SUPPLY INDICES	UNITS	Q1
Total Energy Transmitted	GWh	5846.66
Max System Demand	MW	3469.00
Average Demand MW	MW	2647.94
Load Factor	%	76.33%
Utilization Power Factor	%	0.00%
Transmission Line Availability		
69KV	%	99.62%
161KV	%	99.60%
225KV	%	95.29%
330KV	%	99.73%
System Availability	%	99.58%
Index of Transmission Reliability	%	99.83%
Number Of Lines Outage		
Planned		128
Unplanned		170
Reliability Indices		
SAIDI (Excluding Planned Outages)	hh:mm	0:58
SAIFI (Excluding Planned Outages)		1.22
Average Feeder Availability		
Including Planned Outages		99.94%
Excluding Planned Outages		99.95%
Worst Performing ECG Feeder		
Feeder Name	ID	14F2
Availability	%	98.67%
Worst Performing Ned Feeder		
Feeder Name	ID	35T1Y
Availability	%	99.99%

SYSTEM SUPPLY INDICES	UNITS	Q1
ECG Feeder Availability		
Including Planned	%	99.91%
Excluding Planned	%	99.91%
NED Feeder Availability		
Including Planned	%	100.00%
Excluding Planned	%	100.00%
Load Shedding Events		
Automatic Load Shedding (AFLS)		
Number of incidence		3
Total Duration	hh:mm	3:12:00
Manual Load Shedding		
Number of incidence		43
Total Duration	hh:mm	47:00:00
Frequency Deviation		
% Of times frequency was within limits	%	81.91%
% Of times frequency was outside limits	%	18.09%