



PUBLIC UTILITIES REGULATORY COMMISSION (PURC)

Public Utilities Regulatory Information Systems (PURIS)

3rd Quarter, 2021



- **Total Energy Transmitted(GWh):**
5,058.88
- **Max System Demand (MW):**
3,172.00
- **Average Demand (MW):**
2,291.16
- **Load Factor (%)**
72.23%

Number of Lines Outages

- **Planned (#):**
99
- **Unplanned (#):**
180

Automatic Load Shedding

- **Number of Incidences (#):**
1
- **Total Duration (hh:mm):**
0:13


Manual Load Shedding

- **Number of Incidences (#):**
13
- **Total Duration (hh:mm):**
33:40

SAIDI: System Average Interruption Duration Index

SAIFI: System Average Interruption Frequency Index

Performance Statistics



FREQUENCY DEVIATION

