



# PUBLIC UTILITIES REGULATORY COMMISSION (PURC)

## Public Utilities Regulatory Information Systems (PURIS)

### 4th Quarter, 2022



- Total Energy Transmitted(GWh): 5,620.19
- Max System Demand (MW): 3,371.00
- Average Demand (MW): 2545.70
- Load Factor (%): 75.28%

#### Number of Lines Outages

- Planned (#): 91
- Unplanned (#): 175

#### Manual Load Shedding

- Number of Incidences (#): 14
- Total Duration (hh:mm): 4:00

**SAIDI:** System Average Interruption Duration Index

**SAIFI:** System Average Interruption Frequency Index

### Performance Statistics

#### FREQUENCY DEVIATION

